


No. 0498

24/07/2026

Certificate for Safe Drinking Water

It is certified that **Garima Vidya Vihar Senior Secondary School, Airport Road, Opposite Bijasan Mata Temple, Indore – 452005** had installation of R.O. and Aqua Guards for facilities provided to the students and staff drinking water purpose and tested parameters of received samples are within the permissible limit specified in IS-10500:2012 hence safe. **This certificate is valid for a period of ONE YEAR with the scope of annual maintenance contract of water purification system.**


Signature ~~Assistant Engineer~~
P.H.E. Deptt.
Mand. Sub-Div. No 8 (IMC) INDORE

Name : ...Mr. A. S. Ansari.

Designation: ~~Assistant Engineer~~
Mand. Sub-Div. No 8 (IMC) INDORE


Principal
Garima Vidya Vihar Sr. Sec. School
Airport Road Opp. Bijasan Mata
Temple Indore - 452005 (M.P.)



AQC LABS

Serving for quality...



TC-10795

AQC LABS Pvt. Ltd.

14-B, Sneh Nagar, 201-202-203-204, II Floor,
Sapna Sangeeta Main Road, Indore (M.P.)

Ph.: 0731-4903481, 93996-95236

E-mail: testing@aqclabs.com, web: www.aqclabs



TEST REPORT

Test Report No	AQC/2627/07/15/56488	ULR No	TC1079526000010030F
----------------	----------------------	--------	---------------------

Issued To:	Garima Vidya Vihar School Airport Road, Indore (MP)
------------	--

Sample Particulars

Name of Sample	RO Water	Brand Name	--
Sample Drawn By	Customer	Batch No	--
Sample Quantity	1 Ltr	Batch Size	--
Packing Condition	Sealed	Date of Receipt	15/07/2026
Samples Condition	Complies	Date of Testing	16/07/2026
Date of Mfg	--	Date of Completion	22/07/2026
Use By Date	--	Date of Issue	22/07/2026
Letter No.	--	License No.	--
Other Details	RO Water		

Test Results

Sr. No.	Test Parameter	Unit	Specification	Result	Test Method
Table 1: Chemical & Microbiological Parameters					
1	pH value	-	6.5-8.5	6.55	IS 3025 Part 11 : 2022
2	Turbidity	NTU	Max 1.0	Nil	IS 3025 Part 10 : 2023
3	Total Dissolved Solids (TDS)	mg/l	Max 500	127.0	IS 3025 Part 16 : 2023
4	Total Hardness	mg/l	Max 200	75.10	IS 3025 Part 21 : 2009
5	Total Alkalinity	mg/l	Max 200	12.0	IS 3025 Part 23 : 2023
6	Chloride	mg/l	Max 250	34.76	IS 3025 Part 32 : 1988
7	Calcium	mg/l	Max 75	19.80	IS 3025 Part 40 : 1991
8	Magnesium	mg/l	Max 30.0	6.33	FSSAI Manual Analysis No. 14.022:2024
9	E.coli	MPN/100 ml	Shall Be Absent	Absent	IS 1622 : 1981
10	Coliform	MPN/100.ml	Shall Be Absent	Absent	IS 1622 : 1981

Remark : NA

Specification as per IS 10500:2012(Drinking Water).

-----End of the Report-----

[Signature]
Principal
Garima Vidya Vihar Sr. Sec. School
Airport Road Opp. Bijsan Mata
Temple Indore - 452005 (M.P.)

[Signature]
A.Jain, QM
Checked by

[Signature]
R. Manoj, Technical Manager
Authorized by